

MOTOR STARTER SWITCH, MANUAL (LABEL)

Part Number: 23838

DESCRIPTION:

This option provides manual start and stop controls for a motor starter on a batch plant.

OPERATION:

- The operator pushes the MOTOR START button to start the motor starter.
- The operator pushes the MOTOR STOP button to stop the motor starter.

SYSTEM REQUIREMENTS:

- MOTOR START output - an unassigned I/O position that is controlled by a pushbutton on the Manual Station.
- MOTOR STOP input - an unassigned I/O position that is controlled by a pushbutton on the Manual Station.

IMPLEMENTATION:

- Install the output and input Opto modules in the correct slots in the J-Box.
- Configure the pushbuttons on the Manual Station.

www.commandalkon.com

Command Alkon Headquarters

1800 International Park Drive, Suite 400
Birmingham, Alabama 35243
Phone: 1-205-879-3282
Toll Free: 1-800-624-1872
Fax: 1-205-870-1405