

ON/OFF SWITCH, MANUAL (LABEL)

Part Number: 23833

DESCRIPTION:

This option provides either a maintained or a momentary pushbutton for manual control of a specific plant function.

OPERATION:

- Maintained Pushbutton: The operator pushes the button to start the plant function. The operator pushes the button again to stop the plant function.
- Momentary Pushbutton: The operator pushes and holds down on the button to start the plant function. The operator releases the button to stop the plant function.

SYSTEM REQUIREMENTS:

- An unassigned I/O position that is controlled by a pushbutton on the Manual Station.

IMPLEMENTATION:

- Install the Opto module in the correct slot in the J-Box.
- Configure the pushbutton on the Manual Station.

www.commandalkon.com**Command Alkon Headquarters**

1800 International Park Drive, Suite 400

Birmingham, Alabama 35243

Phone: 1-205-879-3282

Toll Free: 1-800-624-1872

Fax: 1-205-870-1405